



Acoustical Absorption Coefficient according to ISO 354

Object: TOPPERFO® wall- and ceiling panelling  
Type TOPPERFO® T 16/16/10-3Research: Laboratory: SWISSCOM AG  
Test area: 12 m<sup>2</sup>  
Echo space volume: 214.3 m<sup>3</sup>01.06.2007  
Relative atmospheric humidity: 50.2%  
Temperature: 20 degreesTOPPERFO® T 16/16/10-3  
Acoustic fleece

Mineral wool 30 mm

**Suspension height:****56 mm**

Cavity 10 mm



## Acoustical Absorption - Medium values


Low frequency range (100-315 Hz): 0.44

Medium frequency range (400-1250 Hz): 0.81

High frequency range (1600-5000 Hz): 0.27

Freq.

[Hz]	Terz
100	0.09
125	0.14
160	0.26
200	0.49
250	0.72
315	0.95
400	1.10
500	1.06
630	0.93
800	0.73
1000	0.60
1250	0.45
1600	0.37
2000	0.33
2500	0.27
3150	0.24
4000	0.21
5000	0.18

**Suspension height 56 mm****NRC**  
**0.68**